

## Classification Report

Number	20-004300-PR01 (NW-A01-02-en-01)
Owner	ALUMINCO S.A. Megali Rahi 32011 Inofita Viotias Greece
Product	Lift-sliding door, scheme D
Designation	System: SL320 Shipping name: SL320
Details	Manufacturer ALUMINCO S.A., - Inofita Viotias; Material Aluminium; Type of opening Lifting sliding; Opening direction Sash left before sash right; Overall dimensions (W x H) 2600 mm x 2400 mm
Special features	Test sequence. Increased operating forces. The vapour pressure equalisation of the glazing rebate has to be ensured. Material compatibility must be taken into account. Material durability must be taken into account. Construction with visible internal drainage. The strength, durability and material compatibility of the adhesive system was not part of the test and is tested separately.

### Result

Air permeability according to EN 12207:2016-12



**Class: 4**

Resistance to wind load according to EN 12210:2016-03



**Class: C3/B4**

Watertightness according to EN 12208:1999-11



**Class: 7A**

ift Rosenheim  
15.12.2020



Thomas Stefan, Dipl.-Ing. (FH)  
Head of Testing Department  
Building Component Testing



Dimitrios Moustakidis, MSc, Dipl.-Ing.  
Operating Testing Officer  
Building Component Testing

### Basis \*)

EN 14351-1:2006+A2:2016-09  
\*) and corresponding national versions  
(e.g. DIN EN)

Test report: 20-004300-PR01 PB-  
A01-02-en-01

### Representation



### Instructions for use

The Evidence ("Nachweis") can be used for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The results obtained apply to the direct field of application determined in Annex E of EN 14351-1.

### Validity

There is no time limit.  
When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

### Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

### Identity-Check



[www.ift-rosenheim.de/ift-geprueft](http://www.ift-rosenheim.de/ift-geprueft)  
ID: 223-18DB6