



**NFRC SIMULATION IN ACCORDANCE WITH
ANSI/NFRC 100, ANSI/NFRC 200 and NFRC 500**

CLEB laboratory Inc.	Submitted to:	Reissued To:
Report No.: NS-02757-1 Rev.1 Reissued Report No.: N/A	Aluminco S.A. Inofita Greece 32011 +30 22620 47000	N/A

Report Summary			
Operation Type:	DATT	Product Line ID Number:	N/A
Series/Model:	AL 450	Report Type:	Initial Certification
Report Date:	2016-10-28	Simulation Date :	2016-10-28
Revision Date:	2017-04-18	Number of Pages:	6

Reissue Information			
Model:	N/A	Date of Reissue:	N/A
Reason for submittal:	N/A	Revision Date:	N/A
Product Line ID Number:	N/A		

Validation test sample configuration			
Operation Type:	DATT	Door description:	N/A
Series/Model:	AL 450	Panel	N/A
Frame Type:	AT	Core Fill:	N/A
Sash Type:	AT	Skin:	N/A
Reinforcement:	None	Sub-Structure:	N/A
Size:	1200 mm W. x 1500 mm H. (47.24" x 59.06")		

Glazing: FZTE_SB70XL#2-Arg90-ClrPPG

Type: Double Sealed Unit
 Spacer Type: S6-D
 Overall Thickness: 28.98 mm (1.14")
 Filling Technique: Single probe
 Design Gas Fill: Argon/Air
 Gas Concentration: 90% Argon, 10% Air

	Thickness		Emissivity							
	mm	inch	S1	S2	S3	S4	S5	S6	S7	S8
Glass 1	5.0	0.20	0.842	0.018						
Glass 2	6.0	0.24			0.840	0.840				
Glass 3	N/A	N/A					N/A	N/A		
Glass 4	N/A	N/A							N/A	N/A
Gap 1	17.98	0.71								
Gap 2	N/A	N/A								
Gap 3	N/A	N/A								

U:2.07 W/(m².K); 0.36 BTU/(hr.ft².F)

Note: Reference must be made to CLEB laboratory Inc. complete report for specimen description and detailed simulation results.

Simulated by:

Dave Deshaies Mc Mahon, Eng.
 Simulator, Thermal Evaluation
 CLEB laboratory Inc.

Approved by:

Ingrid Volbert
 NFRC Certified Simulator, Person in Responsible Charge
 CLEB laboratory Inc.

Montréal
 1320 boul. Lionel-Boulet
 Varennes, Québec J3X 1P7
 montreal@cleb.com
 www.cleb.com
 T 855.353.CLEB (2532)

Québec
 420 boul. Charest Est, suite 300
 Québec, Québec G1K 8M4
 quebec@cleb.com

Ottawa
 29 Capital Drive, suite 200
 Ottawa, Ontario K2G 0E7
 ottawa@cleb.com

Truro
 64 Inglis Place, suite 203
 Truro, Nova Scotia B2N 4B4
 truro@cleb.com

New York
 747 Third Avenue, 2nd Floor
 New York, NY 10017
 newyork@cleb.com