

Classification Report

Number	20-001577-PR01 (NW-A01-02-en-01)
Owner	ALUMINCO S.A. Megali Rahi 32011 Inofita Viotias Greece
Product	Side-hung window with fixed light
Designation	System: W4750 Shipping name: W4750 - side hung with fixed light
Details	Manufacturer ALUMINCO S.A., - Inofita Viotias; Material Aluminium system with thermal break; Type of opening Turn; Opening direction DIN right, inward opening; Overall dimensions (W x H) 1600 mm x 1400 mm
Special features	Test sequence. Position of locking. Increased operating forces. Material compatibility must be taken into account. Material durability must be taken into account. The strength, durability and material compatibility of the adhesive system was not part of the test and is tested separately.

Result

Air permeability according to EN 12207:2016-12



Class: 4

Resistance to wind load according to EN 12210:2016-03



Class: C5/B5


Watertightness according to EN 12208:1999-11




Class: E1200

ift Rosenheim

14.04.2020



Robert Kolacny, Dipl.-Ing. (FH)
Deputy Head of Testing Department
Building Component Testing



Dimitrios Moustakidis, MSc, Dipl.-Ing.
Operating Testing Officer
Building Component Testing

Basis *)

EN 14351-1:2006+A2:2016-09
*) and corresponding national versions
(e.g. DIN EN)

Test report: 20-001577-PR01 PB-
A01-02-en-01

Representation



Instructions for use

The Evidence ("Nachweis") can be used for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The results obtained apply to the direct field of application determined in Annex E of EN 14351-1.

Validity

There is no time limit.
When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

Identity-Check



www.ift-rosenheim.de/ift-geprueft
ID: 861-4658D