

## Classification Report

Number	21-002310-PR01 (NW-C01-05-en-01)
Owner	ALUMINCO S.A. Megali Rahi 32011 Inofita Viotias Greece
Product	burglar resistant single leaf external aluminium pedestrian doorset
Designation	System: D75
Details	Manufacturer ALUMINCO S.A., Inofita Viotias; Material Aluminium system with thermal break; Attack side Closing face as per EN 12519; Overall dimensions (W x H) 1000 x 2200mm; 3-point-lock, auxiliary lock with hook and bolt: Manufacturer KfV Karl Fliether GmbH & Co. KG, Velbert; Designation MFS AS3600SL, T0XP6-24S35928MLR31B001M1; Profile cylinder: Manufacturer ASSA ABLOY Eastern Europe, Bjelovar; Designation TEA T70; Note acc. to EN 1303: on digit 7: class 5, on digit 8: class D; three-part hinge: Manufacturer Master S.r.l., Conversano BA; Designation ED090-330; Number 4

Special features

### Result

Burglary resistance according to EN 1627:2011-05



**Class: RC 2**

### Basis \*)

EN 1627:2011-05

\*) and corresponding national versions (e.g. DIN EN)

Test report: 21-002310-PR01 PB-C01-05-en-01

### Representation



### Instructions for use

The results obtained apply to the field of extended application as set out in EN 1627, Annex D.

### Validity

There is no time limit.

When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

### Notes on publication


The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

ift Rosenheim

25.10.2021



Simon Stürer  
Deputy Head of Testing Department  
Security/Safety Testing



Roman Rubensdörffer  
Operating Testing Officer  
Security/Safety Testing

Identity-Check



[www.ift-rosenheim.de/ift-geprueft](http://www.ift-rosenheim.de/ift-geprueft)  
ID: EE3-452AE