

# ift-Nachweis

## Classification Report



Number	21-002310-PR02 (NW-C01-05-en-01)
Owner	ALUMINCO S.A. Megali Rahi 32011 Inofita Viotias Greece
Product	single burglar resistant external pedestrian doorset
Designation	System: D90
Details	Manufacturer ALUMINCO S.A., Inofita Viotias; Material Aluminium system with thermal break; Attack side Closing face as per EN 12519; Overall dimensions (W x H) 1000 mm x 2200 mm; 3-point-lock, secondary lock designed as hooks and bolts; Manufacturer KfV Karl Fliether GmbH & Co. KG, Velbert; Designation MFS AS3600SL-T0XP6-24S35928MLR31B001M1; double profile cylinder: Manufacturer ASSA ABLOY Eastern Europe, Bjelovar; Designation TESA T70; Note acc. to EN 1303: class 5 digit 7, class D digit 8; Hinge: Manufacturer SIEGENIA-AUBI KG, Beschlag- und Lüftungstechnik, Wilnsdorf-Lehnscheid; Designation two-part concealed aluminium hinge, EA590-323; Number 4

Special features

### Result

Burglary resistance according to EN 1627:2011-05



**Class: RC 2**

ift Rosenheim

13.10.2021

*S. Stürer*

Simon Stürer  
Deputy Head of Testing Department  
Security/Safety Testing

*Roman Rubensdörffer*  
Roman Rubensdörffer  
Operating Testing Officer  
Security/Safety Testing

### Basis \*)

EN 1627:2011-05

\*) and corresponding national versions  
(e.g. DIN EN)

Test report: 21-002310-PR02 PB-C01-05-en-01

### Representation



### Instructions for use

The results obtained apply to the field of extended application as set out in EN 1627, Annex D.

### Validity

There is no time limit.

When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

### Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

Identity-Check



[www.ift-rosenheim.de/ift-geprueft](http://www.ift-rosenheim.de/ift-geprueft)  
ID: 7C2-8EC92